



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2021 T/J(114/2021)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

11 March 2021

Welson Metal & Sanitary Ware MFY
Blk F, 18/F & Blk G&H, 19/F, Phase 1,
Superluck Industrial Center,
45-53 Sha Tsui Road, Tsuen Wan,
N.T., Hong Kong

(Attn.: Mr Ken MA)

Dear Sir,

**Approval of "ATA" Bib Tap
(General Acceptance No. C20210245)**

Your letters ref. WEL-3601-12292020AP and WEL-3601-02062021AP-C1 dated 29 December 2020 and 6 February 2021 respectively refer.

Having considered the test report ref. 204471PC200230 issued on 28 December 2020 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Welson Metal & Sanitary Ware MFY

Country of Origin: the Mainland of China

Brand: ATA

Details of Fitting: 1/2" Bib tap

Model: 3601

Body Markings:



Expiry Date: 7 December 2025

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only